



HPI Verification Services

Test Certificate

Fire Test for Quarter-turn Valves According to API 607:2016

Certificate Number HPIVS/P1001-393-01
 Date of Issue 06-Aug-18
 Manufacturer Ningjin Huamei Machinery Co., Ltd.
 Economic and Technological Development Zone of Ningjin County Dezhou City,
 Shandong Province

Inspection Requested By Ningjin Huamei Machinery Co., Ltd.

	Tested Valve	Qualified Range
Valve Type	D72R-CL150-NPS4	D72R
Test Valve Description	Double Eccentric Butterfly Valve	Double Eccentric Butterfly Valve
Valve Size	NPS 4	NPS 4, 5, 6, 8
Pressure Rating	Class150	Class 150, 300
Valve Body Material	WCB	Ferritic Steel

Scope of Inspection

Performance and fire tests have been carried out on the valves according to manufacturer's instructions in accordance with API 607:2016 standards requirements. Results are within the limits of standards.

Tests have been witnessed by Hpi Verification services. Test results have been accepted and test reports have been reviewed and approved.

Reference documents used for inspection API 607: 2016
 Place & date of inspection Oubei Town, 7 Jun 2017
 Test Report No. FM201706014 dated on 21 Jun 2017
 Test Laboratory & Accreditation National Quality Supervision and Inspection Centre of Valves Products
 (Zhejiang Valve Product Quality Testing Centre)
 CNAS accreditation No CNAS L4638

Inspected & Tests Witnessed by Walter Yang

Check this certificate is genuine



Managing Director

Technical Director



EU Notified Body No. 1521
Company registered in England #7217086

© HPI Verification Services Ltd. 2014

Tel +44 1491 822818
Fax +44 700 600 6831
Email enquiries@eucertification.com
www.eucertification.com

HPI Verification Services Ltd.
The Manor House
Howbery Park, Wallingford
OX10 8BA, United Kingdom