





HPi Verification Services

Test Certificate

Fire Test for Quarter-turn Valves According to API 607:2016

Certificate Number

Date of Issue 06-Aug-18

Ningjin Huamei Machinery Co., Ltd. Manufacturer

Economic and Technological Development Zone of Ningjin County Dezhou City,

Shandong Province

HPiVS/P1001-393-02

Ningjin Huamei Machinery Co., Ltd. Inspection Requested By

	Tested Valve	Qualified Range
Valve Type	D372R-CL150-NPS8	D372R
Test Valve Description	Double Eccentric Butterfly Valve	Double Eccentric Butterfly Valve
Valve Size	NPS 8	NPS 8 and Larger
Pressure Rating	Class150	Class 150, 300
Valve Body Material		Ferritic Steel

Scope of Inspection

Performance and fire tests have been carried out on the valves according to manufacturer's instructions in accordance with API 607:2016 standards requirements. Results are within the limits of standards.

Tests have been witnessed by Hpi Verification services. Test results have been accepted and test reports have been reviewed and approved.

Reference documents used for inspection

Place & date of inspection

Test Report No.

Test Laboratory & Accreditation

Inspected & Tests Witnessed by

API 607: 2016

Oubei Town, 07 Jun 2018

FM201806022 dated on 02 Jul 2018

National Quality Supervision and Inspection Centre of Valves Products

(Zhejiang Valve Product Quality Testing Centre)

CNAS accreditation No CNAS L4638

Walter Yang



Managing Director

The same

Technical Director



EU Notified Body No. 1521

Company registered in England #7217086

© HPi Verification Services Ltd. 2014

+44 1491 822818

+44 700 600 6831

Email enquiries@eucertification.com www.eucertification.com

HPi Verification Services Ltd. The Manor House

Howbery Park, Wallingford OX10 8BA, United Kingdom